



LB-073-TEST

TESTING | INVESTIGATION | ASSURING

176044

LABORATORY TEST REPORT FOR POTABLE WATER

Page 1 of 1

Client Detail	Name	Water Club c/o Collector Consulting FZ LLC	Lab ID Detail	Date	06/01/2018
	Address	Bldg 8, Office 415, Media City, Dubai, UAE P O Box 390549, Dubai, United Arab Emirates		Report Number	17 6044
	Nature of Business	Drop-It Member and Supplier		Sample Number	17 6044
	Reference	Potable Water (After)		Sampling Report No.	17 Not Applicable


Sample Detail	Sample Type	Liquid (Potable Water)	On-site Obs./Tests:	
	Sampling Point	Not Given	pH / Temperature	Not Applicable
	Sampling Location	Adia Building Floor 1, Abu Dhabi	Appearance	Clear Colorless Liquid
	Sample Process	Potable Water		

Sampling Detail	Apparatus	Not Given	Method	APHA AWWA 1060 (#)
	Size	Plastic (1*1.5 L)	Collected by	Client Representative
	Sampling Date	27/12/2017	Delivered by	Client Representative
	Receiving Date	27/12/2017	Time 11:30 Hrs	Received by

Results of Chemical Analysis			Date of Analysis		27/12/2017 - 04/01/2018
Parameter	RESULT	Limits (USEPA) max	Unit	Lab Detection Limit	Test Method (#)
pH @ 25 °C *	7.3	6.5 - 8.5	-	0.1	APHA - AWWA 4500 H ⁺ B
Electrical Conductivity *	259.0	-	µS/cm	0.1	APHA - AWWA 2510 B
Total Dissolved Solids @ 180 °C *	158	500	mg/L	9	APHA - AWWA 2540 C
Chloride as Cl ⁻ *	52	250	mg/L	1	APHA - AWWA 4500 Cl ⁻ B
Cyanide as CN ⁻ *	< 0.002	-	mg/L	0.002	Pyridine - Pyrazalone Method
Fluoride as F ⁻ *	< 0.02	4.0	mg/L	0.02	USEPA SPADNS Reagent Method
Cadmium as Cd *	< 0.002	-	mg/L	0.002	
Chromium as Cr *	< 0.006	-	mg/L	0.006	
Copper as Cu *	0.013	1.3	mg/L	0.006	
Iron as Fe *	0.012	0.3	mg/L	0.011	
Lead as Pb *	< 0.015	0.015	mg/L	0.015	APHA - AWWA 3030 E / 3120 B
Manganese as Mn *	0.003	0.05	mg/L	0.002	
Nickel as Ni *	< 0.005	-	mg/L	0.005	
Zinc as Zn *	0.020	5.0	mg/L	0.006	

Results of Microbiological Analysis			Date of Analysis		27/12/2017 - 04/01/2018
Parameter	RESULT	£ GSO 149/2014 E	Unit	Lab Detection Limit	Test Method (#)
Total Bacterial Count	50	500 ^s	CFU/ml	-	APHA-AWWA 9215 B
Total Coliforms	Not Detected	ND	CFU/100 ml	-	APHA-AWWA 9222 B
Escherichia coli	Not Detected	ND	CFU/100 ml	-	APHA-AWWA 9222 G
Fecal Coliforms	Not Detected	ND	CFU/100 ml	-	APHA-AWWA 9222 D

Notes	Test Variation	None	Tested by	AC / DT / LV
	Remarks	1) The above tested parameters meets the requirement of the specified limits. 2)* This test is accredited by Dubai Municipality (DAC). 3) ND - Not Detected (<1), CFU - Colony Forming Unit		
	Reference	# APHA-AWWA-WEF 22nd Ed. 2012 Standard methods for the examination of Water and Waste Water. £ Gulf Standard Organisation for Unbottled Drinking Water \$ Guidelines for control of Legionella in water system public health and safety department, Public safety section, Dubai Municipality (Guidelines value for Total Bacterial Count is not available in GSO 149/2010 E Specification)		



For: Murtaza Huseni
Manager (Technical & Operations)
For CORE Laboratory

Results relates only to the items tested.

This report shall not be reproduced except in full, without the written approval of the CORE laboratory.

Form No. TOF-29, Issue : 02 / 01.05.2016 , Rev. : 0/-